

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 193

Date...11.04.2026....

It is certified that an inspection team headed by Mr. Bimal Kumar Rajak.....(Name of Officers with designation) from Assistant Engineer.....PHED Inspected the SHANTI-SMRITI" SAMBRAWANA AWASIYA UCHCHA VIDYALAYA, SHUBH NARAYAN NAGAR ARA-SALEMPUR MARG, MAJRAWAN ARA, BHOJPUR, BIHAR on 11.04.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no.....64.....dated 11.04.2026 of District Lab P.H. Division Ara (PHED Lab) certified that the SHANTI-SMRITI" SAMBRAWANA AWASIYA UCHCHA VIDYALAYA (Name of the school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

That certificate is valid till 01.01.2027 yearSignature with Seal.....Name.....Sub divisional OfficerDesignation.....P.H. Sub-divisionName & Address of the Office/Department:.....Ara.....

To

SHANTI-SMRITI"SAMBRAWANA AWASIYA UCHCHA VIDYALAYASHUBH NARAYAN NAGAR ARA-SALEMPUR MARGMAJRAWAN ARA, BHOJPUR, BIHAR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.

ARA/LAB/25-26 / 11/04/2026
64

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name :Bhojpur
Sample Collected By : Self
Division Name: P. H. Division, Ara

Date of Sampling :- 08-04-2026
Date of Testing :- 11-04-2026

S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters																	Total Coli s	Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22			
						8.13	4.2	410	266	180	48.09	14.58	19.99	200	0.08	NT	NT	NT	<0.001	-ve	Safe			
Permissible Limit in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	-			
*NT = Not Tested, BDL=Below Detection Limit						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-	-			

[Signature]
11/04/2026
Research Assistant
(Chemist)
P.H. Division, Ara
Research Assistant
DLWQTL,
P.H. Div, Ara